

## Slip Resistance of Pedestrian Surfaces AS/NZS 3661:1; 2003

### TESTING METHOD

Tests were carried out in accordance with AS/NZS 3661:1: 2003 Slip Resistance of Pedestrian Surfaces, Part 1- Requirements, Appendix A "Method for the Measurement of the Coefficient of friction of Wet Surfaces".

### REQUIREMENTS

**Horizontal Surfaces:** When tested in accordance with method set out in Appendix A, the pedestrian surface shall have a mean coefficient of friction of not less than **0.40** and no specimen in that sample shall be less than **0.35**